



CONTRA COSTA HEALTH SERVICES

COMPLAINT, INCIDENT, AND NOTIFICATION REPORT FORM

Type (Circle One): C I N

CASE NUMBER: 170129-03

Received Date: 1-29-17 Received Time: 4:32 PM Received By: MJH Lead: MJH

Incident Date: 1-29-17 Incident Time: 3:42 PM Assigned to: — Assigned Date: —

COMPLAINANT / REPORTING PARTY:

Name: Sheriff Office Dispatch RP is from Facility Anonymous

Organization: _____

Primary Phone Number: (925) 646-2441 Secondary Phone Number: _____

Email: _____

Address: _____

City: _____ State: _____ Zip Code: _____

FACILITY / LOCATION OF INCIDENT:

Name: Delta Energy Plant CUPA Facility I.D.: 77-3111

Phone Number: (925) 252-2060

Address: 1200 Arcy Lane Unit: -

City: Pittsburg State: CA Zip Code: 94565

Location Description: fire @ 3rd floor generator-deck, release @ outfall

INITIAL INCIDENT DESCRIPTION:

Fire at generator-lube oil & hydrogen.

INCIDENT TYPE / DESCRIPTION:

Community Warning System Level (Circle Highest Level): N/A 0 1 2 3

FACILITY	ISO / MCAR	TRANSPORTATION	MISCELLANEOUS
<input checked="" type="checkbox"/> Fire or Explosion	<input type="checkbox"/> Fatality (one or more)	<input type="checkbox"/> Tank Truck	<input checked="" type="checkbox"/> Storm Drain/Creek
<input checked="" type="checkbox"/> Spill or Release	<input type="checkbox"/> > 24 hrs. Hospital, 3 or more people	<input type="checkbox"/> Railroad	<input type="checkbox"/> Drug Lab
<input type="checkbox"/> Startup or Shutdown	<input type="checkbox"/> Flammable Vapor Cloud > 5,000 lbs.	<input type="checkbox"/> On Water	<input type="checkbox"/> Disposal/Abandonment
<input type="checkbox"/> Flaring		<input type="checkbox"/> Pipeline	<input type="checkbox"/> Odor Complaint
<input type="checkbox"/> Upset		<input type="checkbox"/> Fuel Tank	<input type="checkbox"/> Other:

Time Enroute to Scene: 4:42 PM Time Arrived On Scene: 5:20 PM Time Departed From Scene: 7:30 PM

REFERRED TO OTHER AGENCY:

DTSC STATE FUNDING (if applicable):

CLU/ERER Number: _____

STORMWATER STATUS (if applicable):

Actual Discharge Potential Discharge



AGENCIES ON SCENE OR NOTIFIED:

Agency Type	Agency	O/N	Contact Person	Phone Number	Case Number
Fire Department	Con Fire		Peter Marshall	383 5049	17007556
Law Enforcement					
Air District					
State OES					
	Delta Energy		Victor Shaw	252 2060	-
	VSCG		Lt. M. Mervar	510697-9664	sectorimal1@gmail.com

REPORT:

01-29-17 432 pm MTHagen rec'd S.O. page
 433 pm returned call. Activated
 442 pm Activated on call IR Team

Delta Energy Plant had a fire at the generator. Hydrogen involved, also tube out, confire on scene.

500PM S11, S20, S18 to respond in HMI Depart HQ

5:05 PM S2, S25 respond in HM3 Depart HQ

520PM HMI on scene
 MTHagen made contact with IC (Peter Marshall - B.C.B)
 Fire is out

530pm Delta operators in the process of purging hydrogen.
 Barbara McBride Delta EH&S Dir. shows CCHS Haz Mat outfall where some oil from generator was observed.

Continued →

Additional Required Items: Bill of Lading, Invoice Request Form, and Site Safety Plan

Report Prepared by: MTH

Continued
1-29-17

534 * Safety Briefing *
535 CCHS deploys booms

Delta operators explained they have started the hydrogen purge s.o.p. takes about 3 hours (CO₂ followed by air)

IC/CCHS/Delta operators (Lead is Victor Shaw) had discussion about air monitoring on generator deck. Decision was made to have Delta operators monitor air for confire so they may inspect the site of the fire (generator deck).

725pm CCHS checked out with IC

730pm HM1/HM3 depart scene

800pm Arrive @ HQ Rehab HM1/HM3

~~MJH~~



Hazardous Materials Spill Update: Cal OES Control #:17-0882
Warning Center to: melissa.hagen

01/30/2017 03:10 PM

Governor's Office of Emergency Services
Hazardous Materials Spill Update
CONTROL #: 17-0882 NRC#:

NOTIFY DATE/TIME: 01/29/2017 / 1648
RECEIVED BY: Kristie Jones-Holstrom | OCCURENCE
DATE/TIME:1/29/2017 / 1543
CITY/OP. AREA: Pittsburg/Contra Costa County

1.a. PERSON NOTIFYING Cal OES
PERSON CALLING Cal OES: Colin Oneil | AGENCY: Contra Costa Fire
PHONE #: 925-941-3330 | EXT: | PAGER #(CELLPHONE):

1.b. PERSON REPORTING SPILL (If different from above):
PERSON CALLING Cal OES: | AGENCY:
PHONE #: | EXT: | PAGER #(CELLPHONE):

SUBSTANCE TYPE:

a. SUBSTANCE: / b.QTY: Amount / Measure / c. TYPE / d. OTHER / e.
Pipeline / f. Vessel Over => 300 tons

1. Oil, / unknown / Gal(s) / PETROLEUM / / No / No

2.

3.

4.

*Est ~150 gal
Turbine oil*

Original Description: A steam turbine generator is on fire, causing the release of material. Some of the material is vaporizing and some of the material is leaking on to pavement and traveling towards the San Joaquin River. Water is not involved at this time, however there is potential for material to reach water. Unknown remedial actions at this time. County HAZMAT is en route.

Update(s): 01/29/2017 06:50:45 PM - Received NRC# 1169801, CALLER REPORTED A GENERATOR DISCHARGED OIL DURING A SMALL FIRE. THE OIL WAS WASHED TO SECONDARY CONTAINMENT AND WENT INTO A NEARBY STORM DRAIN. BOOMS APPLIED

Release Secured: YES

; 01/30/2017 03:07:11 PM - The caller states oil from the release went to their property and they are working with the responsible party to obtain a contractor and remediate the situation.

PERSON NOTIFYING Cal OES OF SPILL UPDATE:

NAME: Scott Etzel | AGENCY: Dow Chemical
PHONE #: 925-432-5410 | EXT: | PAGER #(CELLPHONE):

UPDATE QUANTITY:

1. Amount: Gal(s)
2. Amount:
3. Amount:
4. Amount:

UPDATE RECEIVED BY: Kristie Jones-Holstrom

UPDATE KNOWN IMPACT:

UPDATE CAUSE:

SITUATION UPDATE: The caller states oil from the release went to their

property and they are working with the responsible party to obtain a contractor and remediate the situation.

CONFIDENTIAL:

FAX NOTIFICATION LIST: AA/CUPA, DFG-OSPR, DTSC, RWQCB, US EPA, USFWS, AIR RESOURCES BD, LANDS, PARKS & REC, USCG, Co/WP, Co/Hlth, Co/E-Hlth

ADMINISTERING AGENCY: Contra Costa County Health Services Department

SECONDARY AGENCY:

OTHER NOTIFIED:

Created by Warning Center on 1/30/2017 3:07:11 PM
Modified by Warning Center on 1/30/2017 3:09:45 PM

Last

California State Warning Center
Governor's Office of Emergency Services
Phone: (916) 845-8911
Warning.Center@oes.ca.gov